

Example^a

✓
204

Initial Notification of Applicability^b

National Emission Standards for Hazardous Air Pollutants:
Stationary Reciprocating Internal Combustion Engines
40 CFR Part 63 Subpart. ~~ZZZZ~~

REC'D

AUG 31 2010

APCO

☒ Yes, I am subject to 40 CFR Part 63 subpart ~~ZZZZ~~ National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

NAICS code(s): 221112, Fossil fuel power generation

Compliance Date: ☒ Existing source: May 3, 2013 ☐ New/reconstructed source: upon initial startup

Note: The May 3, 2013 compliance date for existing sources applies to the following engine types:

- Existing non-emergency CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE located at an area source of HAP emissions

Company name: City of Osage City Municipal Power Plant

Facility name (if different): _____

Facility (physical location) address: 201 South Fifth Street
Osage City, KS 66523

My facility is a (please choose one): ☐ Major source ☒ Area source
☐ Synthetic minor

Engine # 10 Caterpillar 1,304 Horsepower Diesel

^a This is an example of the type of information that must be submitted to fulfill the Initial Notification of Applicability Status requirement of 40 CFR 63, subpart ~~ZZZZ~~. You may submit the information in another form or format, or you may use this form.

^b Initial Notification is due 120 days after the effective date of the rule or 120 days after you become subject to the rule

Example^a

Owner name/title: City of Osage City

Owner/company address: 201 South Fifth Street

Osage City, KS 66523

Owner telephone number: 785-528-3714

Owner email address (if available): mgilliland@osagecity.com


If the Operator information is different from the Owner, please provide the following:

Operator name/title: John Rice Power Plant Superintendent

Operator telephone number: 785-528-3851

Operator email address (if available): jrice@osagecity.com

I hereby certify that the information presented herein is correct to the best of my knowledge.



(Signature)

Aug. 25, 2010

(Date)

Mike Gilliland / Director of Util. (785) 528-4124

(Name/title) (Telephone No.)